

Tract No. _____ Lot No. _____

CITY OF SAN JOSE

BUILDING DEPARTMENT

APPLICATION FOR BUILDING PERMIT

Pa!

Date 3-6, 19 77 Permit No. 01644Application is hereby made for a permit to RE ROOF
a 1 story, Type ✓ COMMERCIAL Building Use Zone C-3at 370 S. WINCHESTER Occupancy _____to be occupied only as RETAIL STORE Parking Space _____

in accordance with Plans, Specifications and Plot-plan filed herewith. Fire Sprinkler _____

Estimated Value of Improvements, \$ 4000 Emer. Elect. _____

I certify that in the performance of the work for which this permit is issued I shall not employ any person in any manner so as to violate the workmen's compensation laws of California.

Owner MRS HOOVER Address _____By P & D ROOFING Address _____

RECORD OF INSPECTION

Foundation _____ Frame _____

Stucco _____ Finish _____

TO, 1/3 OK
PROG 14 OK 3-10-77 SG

Exemption from requirement for State of California Contractor's License is hereby claimed by applicant.
as owner ☐ statement filed ☐

Applicant attests that his State of California Contractor's License # _____
is in full force and effect and properly authorizes this application.

San Jose City Business License # _____

BUILT UP ROOF COVERING

ALL APPLICABLE INFORMATION MUST BE COMPLETED

BEFORE A PERMIT MAY BE ISSUED

☐ THE EXISTING ROOF COVER IS TO REMAIN.

☒ THE EXISTING ROOF COVER IS TO BE REMOVED.

☒ GRAVEL SURFACE. ☐ SMOOTH SURFACE.

TOTAL NO. OF EXISTING ROOF COVERS IS 1

NEW ROOF COVER SPECIFICATIONS: FIRE ZONE 3

1. FOLLOW THE MANUFACTURERS INSTRUCTIONS.
2. REPLACE ALL DAMAGED SHEATHING.
3. REPLACE ALL RUSTY METAL OR VENTS.
4. RAISE ALL JACKS, FLASHINGS AND EQUIPMENT.
5. PRIME METAL AND MASONRY.
6. ALL ANGLES TO BE ASBESTOS FINISH.

MANUFACTURER USG

SPEC. NO. DB1-1 U.L. CLASS C

ROOF SLOPE 0 IN 12" TOTAL SQUARES 65

RIGID INSULATION _____

BASE SHEET 15 LB. FEELT PLUS

3 PLYS OF 15 LB FEELT

USING 25 LB. MOPPINGS PER PLY _____

FLOOD COAT 40 LBS. GLAZE COAT _____ LBS.

GRAVEL 400 LBS. _____

CAP SHEET _____ LB. _____

☒ SELF CERTIFY ☐ INSPECTION AGENCY

☐ PRE-ROOFING INSP. _____

CALL FOR PROGRESS INSPECTION & FINAL INSPECTION